



New Mexico Environment Department - Drinking Water Bureau

Public Notification Certification Form – All Tiers
Requirements Pursuant to 40 CFR 141 (Subpart Q)

**This form and a copy of your Notice to the Public must be submitted to the State within 10 days of notifying your customers. **

PWSID#: NM3522013 Water System Name: Tatum Municipal Water System

Violation or Situation Date: August 12, 2019

Individual Contaminant or Contaminant Group: 45 120-day Ground Water Rule (Treatment Technique)

Violation or Situation Type: Failure to resolve significant deficiencies

Violation or Situation Public Notification Tier: Tier 2

Distributed the notice by the following method(s), and on the following date(s) in accordance with 40 CFR 141.201:

- Continuously Post Date: 8-20-19
Separate Mailing to Customers Date:
Hand Deliver Notice to Customers Date:
Publish Notice in Newspaper Date:
Release Notice to and Announced by Broadcast Media Date:
Post Notice on System Website Date: 8-20-19
Billing Date:
Annual Report (Consumer Confidence Report) Date:
Other: Date:

Attach a copy of the posted Public Notice(s) to this certification form.

The public water system named above hereby certifies that public notification has been provided to its consumers in accordance with all delivery, content, and format requirements specified in 40 CFR Part 141:

Water System Representative: [Signature] Joe Garcia 575-398-4633
(Signature) (Print Name) (Phone Number)

Date of Certification: 6/17/11

IMPORTANT INFORMATION ABOUT YOUR WATER SYSTEM

Tatum Municipal Water System failed to submit corrective action within required timeframe

A routine sanitary survey conducted on 4/9/2018 with the NMED DWB found our water tower did not have a locked ladder gate.

We failed to take action to correct this violation by the deadline of 120 days.

There is nothing the public needs to do. This is just a notification on the results of the survey.

The Town of Tatum has hired Marine Diving Solutions to build a lock for the ladder. We will have this completed by December of 2019.

For More Info, please contact:

Lynn Stevens at 575-398-4633